




OFFICE OF THE SUPERINTENDING ENGINEER
WORKS ESTABLISHMENT SECTION
NATIONAL INSTITUTE OF TECHNOLOGY KARNATAKA, SURATHKAL
POST SRINIVASNAGAR, MANGALURU – 575025 (DK)



Phone: [0824] - 2473029, 2473028
Email: re@nitk.edu.in
Office of the Superintending Engineer
Work Establishment Section
National Institute of Technology Karnataka
Surathkal, P.O. Srinivasnagar- 575025

Fax: [0824] 2474033
Website: <http://www.nitk.ac.in>

No. 157/ Inviting Quotation /19/ 2022-23/DM

Date:26.08.2022

NOTICE INVITING QUOTATIONS

The National Institute of Technology Karnataka, Surathkal (in short - NITK, Surathkal or Institute) is an autonomous Institute of the Govt. Of India [under the Ministry of Education] imparting technical and science education. The Institute intends to “**Providing firefighting system to the NITK Kannada Medium High School**”. The details of work listed on the sheet enclosed. In this connection, sealed quotations are invited by the undersigned subject to the terms and conditions enumerated here under from the Contractor/ agencies so as to reach this office on or before **05.09.2022 by 3:30 PM**. The quotations shall be opened on the same day if possible.

Terms and conditions:

1. The intending bidder shall quote his rates in the 'Quotation Format' enclosed hear with either in his letter head or using the same format. He shall sign each page with seal of the firm. Envelope super scripted as Quotation for “Providing firefighting system to the NITK Kannada Medium High School ”and addressed to as “The Superintending Engineer, NITK, Surathkal, Post Srinivasanagar, Mangaluru – 575025.
2. The GST registration number and the PAN number of the bidder shall be mentioned in the quotation. Quotation without this information will not be accepted.
3. Quotation may be dropped in the Tender Box kept in the office or may be sent by post/ courier. It is the responsibility of the bidder to make sure that the quotation is delivered in time. The quotations received after the due date will not be entertained. The rate quoted shall be valid for 90 days for its acceptance.
4. The bidder shall specify the make of material for which the rate is offered by him. The bidder may quote for multiple brands also. Complete technical details of the quoted item should be submitted along with the quotation.
5. Freight of Rate [F.O.R] – NITK, Surathkal.
6. Terms and conditions stipulated in this notice inviting conditions are binding on the bidder.
7. The Institute can cancel the tender process at any stage if necessary.


Superintending Engineer
NITK Surathkal
Superintending Engineer
Work Establishment Section
National Institute of Technology Karnataka
Surathkal, P.O. Srinivasnagar- 575025

Name and Address of the Bidder:

Contact No:

GST registration number:

PAN number: -

No:

Date:

QUOTATION

To,

The Superintending Engineer,
NITK, Surathkal.

Sir,

Sub: Providing firefighting system to the NITK Kannada Medium High School.

Sl. No.	Specification	Quantity	Rate	Tax	Amount
1.	Supply, erection, testing & commissioning of electrical motor driven submersible pump capable to deliver 450 LPM (5.0Hp). The pump shall be coupled to TEFC motor of suitable HP with speed of 2900 RPM and complete set.	1.00 No			
2	BOOSTER PUMP CONTROL PANEL Fabricating & Supply, installing, testing and commissioning of control panel for Electrical motor driven pumps. INCOMING Feeder for Suitable HP Booster pumps - 1 No. 1 No. 5.0 A TPN MCCB with back up fuses DOL Starter.	1.00 No			
3.	Supplying, installing, testing and commissioning of C.I. Non-return valves as per IS:5312(PN 10) flap type with required flanges, nuts, bolts and gaskets etc. complete. 50mm dia	1.00 No			
4.	Supplying and installation of Pressure Switch of suitable range for pump sets with Ball valves, Fittings like unions / colors / reducers etc. With unions etc. complete.	1.00 No			
5.	Supplying and fixing dial type make Pressure Gauge with isolation cock and pipe at hydrant station, Dial diameter 150mm calibration 0-15kg	1.00 No			
6.	Supplying, installing, testing and commissioning of CI Ball valves 25mm dia with fittings of screwed end type.	1.00 No			
7.	Supplying, Installing, Testing and commissioning of 0.5KM range siren	1.00 No			

SIGNAGES: Providing and installing in position the following type of sign boards illumination type				
a) " No SMOKING" Signages	1.00 No			
b) "FIRE EXIT" & Floor identification signage (ie, Ground Floor etc) at each stair enclosure on every floor, indicating the floor number in words, lettering size shall be 5 cm with contrasting colour from back ground. Size shall be 15cm x 30 cm.	1.00 No			
c) Providing and fixing in position the signages " FIRE ORDER" it should contain the following matter on 3mm thick "Opaque" PVC foam board of computerised cut, PVC non-reflective self adhesive vinyle painted foam board of 2 x 3.	1.00 No			

Seal and signature of the Bidder