



NATIONAL INSTITUTE OF TECHNOLOGY KARNATAKA, SURATHKAL, SRINIVASNAGAR, MANGALORE-575025

Date: 18.12.2024

Corrigendum No. 01

With reference to the Bid for “15KVA- 3 Phase UPS with 20 Tubular Batteries” for Ref. Number: NITK/EC/OH35-IRG/UPS/Q/955/2024, Dated: 05/12/2024, please note the following:

Additions/Corrections to Technical Specification:

1. **Modified item name:** 15 KVA- 3 Phase UPS with 30 Tubular Batteries (3 phase input – 3 phase output)
2. Specification of Batteries: 12V 100 AH Tubular Batteries (30 Nos)
3. Output power factor: 0.9
4. The supplier is required to maintain the batteries and provided distilled water and other maintainace to be done once in three months till the warranty period.
5. Availability of service centres: The bidder with OEM need to have a functional service centre in Dakshina Kannada District with a local address trade license. The technician should be available during working hours with 24 hours of receiving the complaint.
6. Last date for submission of bids: 03.01.2025 before 3:00 PM
7. Bid opening date: 03.01.2025 at 4:00 PM (If possible).

Sd/-
(BUYER)

Sd/-
HOD
(Dept. of E&C Engineering)